



Product Service

CERTIFICATE

No. Z10 040393 0029 Rev. 02

Holder of Certificate: **Euchner GmbH + Co. KG**

Kohlhammerstr. 16
70771 Leinfelden-Echterdingen
GERMANY

Certification Mark:



Product: **Access-Control System**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: EL93782T

Valid until: 2027-02-23

Date, 2022-02-28

(Christian Dirmeier)

CERTIFICATE

No. Z10 040393 0029 Rev. 02

Parameters:	Operating Voltage:	DC 24 V +20% / -15%
	Ambient temperature:	-25 °C ... +55 °C
	Rated input current:	Max. 955 mA
	Degree of protection	IP65

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report EL93782C in the current valid revision.

Tested according to:	2006/42/EG
	EN 60947-5-3:2013
	EN 61508-1:2010 (SIL 3)
	EN 61508-2:2010 (SIL 3)
	EN 61508-3:2010 (SIL 3)
	EN IEC 62061:2021 (maximum SIL 3)
	EN ISO 13849-1:2015 (Cat 4, PL e)
EN ISO 14119:2013	

Model(s)	MGB2 - compact
-----------------	-----------------------