



Product Service

CERTIFICATE

No. B 040393 0022 Rev. 01

Holder of Certificate: **Euchner GmbH + Co. KG**
Kohlhammerstr. 16
70771 Leinfelden-Echterdingen
GERMANY

Certification Mark:



Product: **Switches**
Safety Door Switch

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 73587303

Valid until: 2026-08-10

Date, 2022-01-10

(Shigehisa Ishikawa)



Product Service

CERTIFICATE

No. B 040393 0022 Rev. 01

Model(s): **NQ series**

Model	Switch configuration
NQ02VZ-5000	2NC
NQ03VZ-5000	3NC
NQ11VZ-5000	1NC+1NO
NQ12VZ-5000	2NC+1NO

Parameters:

Utilization category: AC15: 0.75 A, 240 V AC
DC13: 0.27 A, 250 V DC
DC13: 2.3 A, 30 V DC

Rated insulation voltage: 300 V

Rated conventional free air thermal current: 2.5 A

Pollution degree: 3

Degree of protection: IP 67

Remarks:

- When installing / inserting the equipment, all requirements of the mentioned test standard must be fulfilled.
- See "1.3 Technical Data" on Technical Report No. 73587303.

Tested according to: EN 60947-5-1:2017
GS-ET-15E:2019