



Product Service

# CERTIFICATE

No. Z10 040393 0030 Rev. 01

**Holder of Certificate:** **Euchner GmbH + Co. KG**  
Kohlhammerstr. 16  
70771 Leinfelden-Echterdingen  
GERMANY

**Certification Mark:**



**Product:** **Safety-Related Programmable Systems  
Modular Safety Integrated Controller**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** EL85669T

**Valid until:** 2026-12-01

**Date,** 2022-04-12

( Jiayi Dong )

# CERTIFICATE

No. Z10 040393 0030 Rev. 01

<b>Parameters:</b>	Rated voltage:	24 Vdc $\pm$ 20%
	Operating temperature:	-10 °C ... +55 °C
	Storage temperature:	-20 °C ... +85 °C
	Max. rating relay output:	230 VAC - 6A

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report EL85669T in the current valid revision.

<b>Tested according to:</b>	2006/42/EC
	EN 61131-2:2007
	EN ISO 13849-1:2015 (Cat 4, PL e)
	EN IEC 61496-1:2020 (Type 4)
	EN 61508-1:2010 (SIL3)
	EN 61508-2:2010 (SIL3)
	EN 61508-3:2010 (SIL3)
	IEC 62061:2021 (maximum SIL 3)
EN 81-20:2020	
EN 81-50:2020	

<b>Model(s):</b>	<b>MSC</b>
------------------	------------