

Certificate of Compliance

Certificate: 1777296

Project: 1777296

Master Contract: 234368

Date Issued: April 6, 2006

Issued to: Euchner GmbH + Co. KG KohlhammerstraBe 16 Leinfelden 70771 GERMANY Attention: Mr. Nguyen

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'

Issued by:

Rob Hempstock, AScT.

Authorized by: Terry Nagy Operations Manager

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous (Certified to US Standards)

Limit Switches, Model No NG1XX-510-MY rated A 600 (600 V ac, 10 A, 7200 VA for making/720 VA for breaking) and Q 600 (600 V dc, 2.5 A, 69 VA make and break).

Notes:

- 1. XX may be replaced with letters to indicate the type of actuator mechanism.
- 2. These types of devices are Certified as components for use only in other Certified equipment where the suitability

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

DQD 507 Rev. 2004-06-30





Certificate: 1777296

Master Contract: 234368

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 14-M91	-	INDUSTRIAL CONTROL EQUIPMENT
UL Std. No 508	-	INDUSTRIAL CONTROL EQUIPMENT

MARKINGS

Submittor's name and/or File Number "234368" or trade mark, model designation, electrical rating, date code, or equivalent, and the CSA Monogram with NRTL/C or C/US indicator appear on a CSA and/or UL Accepted adhesive nameplate or ink stamped on the enclosure.

DQD 507 Rev. 2004-06-30

Page 2



Supplement to Certificate of Compliance

Certificate:

1777296

Master Contract: 234368

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1777296	April 6, 2006	Multiple Listing for Euchner GmbH + Co. KG / M/S Teknic Euchner Electronics Pvt. Ltd., Model NG1XX-510-MY / NG1XX-510. (Alternate File No. 234368, Form A)

Multiple Listing Project No	Listee Models	Submittor Models
1777296	NG1XX-510-MY	NG1XX-510 (Report 2500002248)