



Certificate of Compliance

Certificate: 1708516

Master Contract: 231732

Project: 2557682

Date Issued: September 10, 2012

Issued to: Euchner Gmbh & Co. KG
Kohlhammerstr. 16
Leinfelden, 70771
GERMANY

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

Carole Lemay

PRODUCTS

CLASS 3211 83 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices -
CERTIFIED TO U.S. STANDARDS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

- Limit switches, type RPS3131. Rated C300, enclosure type 4X, indoor use only.
- Rope pull switches, with metal enclosure, Types RPS-M-E-3131, rated 10 A, 300 Vac G.P., A300, Q300, CSA enclosure Type 3.

Notes:

- 1 The type designations are completed with suffixes indicating contact arrangement, type of actuator etc.
- 2 Certified as a component for use only where the suitability of the combination is determined by CSA international or another NRTL.
- 3 Switches may be provided with an emergency pushbutton, code rated A300 Q300 and may be provided with one or two contact blocks.



Certificate: 1708516

Master Contract: 231732

Project: 2557682

Date Issued: September 10, 2012

MARKINGS

Listee's name and/or CSA file number 231732, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.

The cCSAus monogram may appear next to the CSA Mark